



CITY OF EL CAJON
Building & Fire Safety Division
200 Civic Center Way
El Cajon, CA 92020
Phone: (619) 441-1726
Fax (619) 441-1743

TENANT IMPROVEMENT FIRE SPRINKLER SYSTEMS

Please read and be aware of the following information!

A tenant improvement fire sprinkler systems is typically an alteration of an existing sprinkler system in order to accommodate a new configuration of walls or ceilings. As such, submittal requirements are typically much different from requirements for new systems. When submitting plans for a tenant improvement fire sprinkler system, please include the following information:

1. List the hazard classification of the occupancy.
2. Include nameplate information from the existing year.
3. Indicate the type of existing system (i.e., pipe schedule, hydraulically designed, etc.)
4. Indicate the design basis for the system (NFPA 13, NFPA 13D, etc.)
5. Indicate the maximum spacing of sprinklers per hazard classification.
6. Show the approximate location and size of all existing branch and feeder lines.
7. Provide specification sheets for all devices.
8. List the use of all rooms and areas of the tenant space.
9. Show location of all sprinklers within the building.
10. Show approximate arm over locations.
11. Provide a detail for typical hanger installation

If you have any questions concerning these submittal requirements please do not hesitate to contact the Building and Fire Safety Division at (619) 441-1726.